

**Government of Jammu and Kashmir**  
**Directorate General Fire & Emergency Services, J&K**  
**Jammu**

**The Principal**  
**M.V. International School**  
**17 Miles, NH-1A, Vijaypur**  
**District Samba**

No: JDF&ES/FP/ 1654

Dated: 28-03.2019

**Sub:** Fire Safety Certificate.

**Ref:** Assistant Director, Fire & Emergency Services, Command Samba-Kathua office letter No. ADSK/1387 dated 24.12.2018.

**Dear Sir,**

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed First Aid Fire Extinguishers, underground water storage tank and Fire Point in school premises. The school is approachable for fire tender in case of any emergency. However the management is advised to adopt the following fire safety measures in letter and spirit:-

1. First Aid Fire fighting system installed in the School building should be checked periodically. Staff and students should be fully trained in handling/ operating of fire fighting system installed in the School building. The management shall intimate the office of Assistant Director, Fire & Emergency Services Command Samba-Kathua after each quarter that the fire fighting equipments installed in the school are functioning.
2. 01 No. of CO<sub>2</sub> Type fire extinguisher of 4.5 Kg. capacity should be provided near main electric switch board panel.
3. An electric / manually operated fire alarm system and public address system should be provided in the building for alerting the students/staff during any emergency.
4. Exit Signs shall be prominently displayed along with exit routes.
5. No Hazardous material should be kept inside or outside of the School premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, the clearance will be treated withdrawn/cancelled.
6. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
7. At present school is double storied, as such no addition/alteration should be made by the school management in the existing structure without prior permission from this department.
8. The validity of this clearance shall remain enforce for one year and same needs to be renewed after checking of fire fighting system installed in the school.

Yours Sincerely



**Director General**  
**Fire & Emergency Services, J&K**  
**Jammu**